

后里

項目	pH	水溫	色度	濁度	硝酸鹽氮	亞硝酸鹽氮	總硬度	大腸桿菌群	溶氧	鉛	自由有效餘氯	氨氮	總有機碳
單位	-	°C	mg/L	NTU	mg/L	mg/L	mg CaCO3/L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
標準值	6-8.5	-	5	2	10	0.1	300	6	-	0.01	0.2-1.0	0.1	-
106.5.3	8.4	27.5	<3	0.2	0.36	N.D	164	<1	-	-	-	-	-
106.7.6	8.3	30.9	<3	0.1	0.4	N.D	164	<1	-	-	-	-	-
106.9.4	8.3	30.2	<3	0.1	0.57	N.D	138	<1	-	-	-	-	-
106.11.9	8.2	29.2	<3	N.D	0.7	N.D	145	<1	-	-	-	-	-
107.1.22	8	20.6	<5	0.60	0.34	<0.01	163	<1	-	-	-	-	-
107.4.10	7.9	25.1	<5	0.15	0.35	N.D	166	<1	-	-	-	-	-
107.7.5	7.6	28.7	<5	0.10	0.17	N.D	172	<1	-	-	-	-	-
107.10.11	7.9	25.7	<5	<0.10	0.63	N.D	141	<1	-	-	-	-	-
108.2.18	8.2	20.2	<5	0.65	0.18	N.D	149	<1	6.8	N.D	<0.02	0.08	0.7
108.4.9	7.7	28.2	<5	0.50	0.20	0.002	160	<1	7.0	N.D	<0.02	N.D	0.7
108.7.2	7.9	31.9	<5	0.40	0.04	N.D	151	<1	5.5	0.002	<0.02	0.05	0.8
108.10.01	7.6	28.1	<5	0.30	0.33	N.D	155	<1	7.2	0.003	<0.02	0.10	0.7

清水(水塔取水)

項目	pH	水溫	硝酸 鹽氮	亞硝酸 鹽氮	總硬度	大腸 桿菌群	砷	鉛
單位		°C	mg/L	CFU/mL	mg CaCO <sub>3</sub> /L	CFU/100mL	mg/L	mg/L
標準值	6-8.5	-	10	100	300	6	0.01	0.01
106.5.3	6.8	26.3	11.1	<1	94.6	<1	N.D	—
106.7.5	6.6	29.4	10.5	71	95	2	N.D	—
106.9.4	6.3	27.9	10.4	4.4*10 <sup>2</sup>	93.3	TNTC	N.D	—
106.11.16	6.2	27.1	10.5	97	89.1	5	N.D	—
107.1.18	6.3	22.8	5.24	8	94.2	1	0.0005	—
107.4.10	7.1	25.1	10.3	43	93.9	5	0.0002	—
107.7.5	6.3	24.5	10.1	78	85.4	<1	0.0004	—

沙鹿(水塔取水)

項目	pH	水溫	硝酸 鹽氮	亞硝酸 鹽氮	總硬度	大腸 桿菌群	砷	鉛	溶氧
單位		°C	mg/L	CFU/mL	mg CaCO <sub>3</sub> /L	CFU/100mL	mg/L	mg/L	mg/L
標準值	6-8.5	-	10	100	300	6	0.01	0.01	-
106.5.3	6.3	25.1	9.54	<1	32.5	<1	N.D	-	-
106.7.5	6.3	27.8	9.33	1.1*10 <sup>2</sup>	30.2	53	<0.0010	-	-
106.9.4	6.1	28.2	9.2	3.4*10 <sup>2</sup>	29.8	TNTC	<0.0010	-	-
106.11.16	5.8	25.7	9.19	2.3*10 <sup>2</sup>	30.0	1.4*10 <sup>2</sup>	<0.0010	-	-
107.1.18	6.8	22.7	7.66	90	27.3	2	N.D	-	-
107.4.10	6.4	25.6	6.8	93	26.3	4	0.0010	-	-
107.7.5	7.0	25.7	7.28	88	27.1	<1	0.0004	-	-

## 大肚(廁所洗手台)

項目	pH	水溫	色度	濁度	硝酸鹽氮	亞硝酸鹽氮	總硬度	大腸桿菌群	溶氧	鉛	自由有效餘氯	氨氮	總有機碳
單位	-	°C	mg/L	NTU	mg/L	mg/L	mg CaCO <sub>3</sub> /L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
標準值	6-8.5	—	5	2	10	0.1	300	6	—	0.01	0.2-1.0	0.1	—
106.5.3	8.4	28.1	<3	0.25	3.13	N.D	88.7	<1	—	—	—	—	—
106.7.5	8.3	29.7	<3	0.15	4.26	N.D	99.5	<1	—	—	—	—	—
106.9.5	7.4	29.2	<3	0.5	4.27	N.D	97	<1	—	—	—	—	—
106.11.16	7.8	26.4	7	1.1	4.10	N.D	95	<1	—	—	—	—	—
107.1.18	7.5	21.7	<5	0.60	4.44	<0.01	86.1	<1	—	—	—	—	—
107.4.10	7.8	25.9	<5	0.20	5.13	N.D	111	<1	—	—	—	—	—
107.7.5	7.8	28.3	<5	0.40	5.13	N.D	106	<1	—	—	—	—	—
107.10.11	8.0	27.4	<5	0.20	4.34	N.D	90	<1	—	—	—	—	—
108.2.14	8.0	23.9	<5	0.30	3.57	<0.01	105	<1	4.4	N.D	0.15	0.16	42.9

## 大肚(清潔隊門口)

108.3.13	6.9	27.4	<5	0.15	0.60	N.D	N.D	<1	7.1	N.D	<0.02	0.03	0.6
108.4.9	7.4	32.7	<5	0.55	0.78	N.D	19.0	<1	6.7	N.D	<0.02	N.D	0.4
108.7.4	7.9	32.3	<5	0.25	0.08	N.D	N.D	<1	6.6	0.006	<0.02	0.10	0.3
108.10.1	6.7	34.8	<5	0.30	0.72	<0.01	120	<1	6.9	0.003	<0.02	0.08	0.5

## 大里滲出水廠

項目	pH	水溫	色度	濁度	硝酸鹽氮	亞硝酸鹽氮	總硬度	大腸桿菌群	溶氧	鉛	自由有效餘氯	氨氮	總有機碳
單位	-	°C	mg/L	NTU	mg/L	mg/L	mg CaCO <sub>3</sub> /L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
標準值	6-8.5	—	5	2	10	0.1	300	6	—	0.01	0.2-1.0	0.1	—
106.5.3	7.2	25.4	<3	N.D	0.8	<0.01	96.6	<1	—	—	—	—	—
106.7.6	7.4	14	<3	N.D	0.39	N.D	22.1	<1	—	—	—	—	—
106.9.5	6.3	29.8	<3	N.D	0.38	N.D	13	<1	—	—	—	—	—
106.11.9	6.4	28.8	<3	0.15	N.D	N.D	N.D	<1	—	—	—	—	—
107.1.22	8.1	25.2	<5	<0.10	0.34	<0.01	4.0	<1	—	—	—	—	—
107.4.10	6.8	28.0	<5	0.10	0.22	N.D	4.0	<1	—	—	—	—	—
107.7.5	7.6	29.1	<5	0.15	0.17	N.D	4.0	<1	—	—	—	—	—
107.10.11	6.6	34.9	<5	0.15	0.86	N.D	4.0	<1	—	—	—	—	—
108.2.14	7.1	25.4	<5	0.15	0.09	<0.01	4.0	<1	8.5	N.D	<0.02	0.11	2.1
108.4.9	6.4	29.9	<5	1.1	0.27	N.D	3.0	<1	3.4	N.D	<0.02	0.09	1.6
108.7.4	6.8	33.2	<5	0.10	0.27	<0.01	N.D	<1	3.7	N.D	<0.02	0.09	0.2
108.10.1	5.9	31.8	<5	0.65	0.37	N.D	4.0	<1	4.5	0.004	<0.02	0.08	1.2

## 大里辦公區

項目	pH	水溫	色度	濁度	硝酸鹽氮	亞硝酸鹽氮	總硬度	大腸桿菌群	溶氧	鉛	自由有效餘氯	氨氮	總有機碳
單位	-	°C	mg/L	NTU	mg/L	mg/L	mg CaCO <sub>3</sub> /L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
標準值	6-8.5	—	5	2	10	0.1	300	6	—	0.01	0.2-1.0	0.1	—
106.5.3	6.9	25.6	<3	N.D	0.2	N.D	1.8	<1	—	—	—	—	—
106.7.6	7.6	13.6	<3	N.D	0.91	N.D	N.D	<1	—	—	—	—	—
106.9.5	6.2	31	<3	0.1	0.93	N.D	3.6	<1	—	—	—	—	—
106.11.9	6.2	29.2	<3	0.1	N.D	N.D	N.D	<1	—	—	—	—	—
107.1.22	7.8	25.4	<5	0.15	0.68	<0.01	2.0	<1	—	—	—	—	—
107.4.10	7.1	25.1	<5	<0.10	0.90	N.D	3.0	<1	—	—	—	—	—
107.7.5	7.7	32.1	<5	0.15	0.42	N.D	12.1	<1	—	—	—	—	—
107.10.11	6.6	32.4	<5	0.20	0.65	N.D	2.0	<1	—	—	—	—	—
108.2.14	7.1	32.7	<5	0.20	0.58	<0.01	3.5	<1	8.5	N.D	<0.02	0.08	2.1
108.4.9	7.2	29.7	<5	0.55	0.68	N.D	4.0	<1	3.8	N.D	<0.02	0.03	0.6
108.7.4	6.9	33	<5	0.30	0.43	<0.01	N.D	<1	3.8	N.D	<0.02	0.09	0.4

文山(掩埋場辦公室)

項目	pH	水溫	色度	濁度	硝酸鹽氮	亞硝酸鹽氮	總硬度	大腸桿菌群	溶氧	鉛	自由有效餘氯	氨氮	總有機碳
單位	-	°C	mg/L	NTU	mg/L	mg/L	mg CaCO <sub>3</sub> /L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
標準值	6-8.5	-	5	2	10	0.1	300	6	-	0.01	0.2-1.0	0.1	-
106.5.3	6.9	25.5	<3	N.D	0.2	N.D	3	<1	-	-	-	-	-
106.7.6	7.6	27.2	<3	N.D	0.2	N.D	11.3	39	-	-	-	-	-
106.9.5	7.2	29.8	<3	N.D	0.33	N.D	4.4	<1	-	-	-	-	-
106.11.9	7.2	29.2	<3	N.D	N.D	N.D	N.D	<1	-	-	-	-	-
107.1.22	7.3	30.2	<5	0.35	0.17	<0.01	12.1	<1	-	-	-	-	-
107.4.10	7.8	28.6	<5	<0.10	0.17	N.D	15.2	<1	-	-	-	-	-
107.7.5	8.5	29.2	<5	0.15	0.11	N.D	N.D	<1	-	-	-	-	-
107.10.11	7.8	28.0	<5	0.15	0.18	N.D	6.0	<1	-	-	-	-	-
108.2.14	7.7	25.6	<5	<0.10	0.04	<0.01	14.1	<1	8.5	N.D	<0.02	0.07	0.6
108.4.9	7.1	28.8	<5	1.8	0.11	N.D	N.D	<1	2.7	N.D	<0.02	N.D	0.2
108.7.4	8.1	29.2	<5	0.7	0.06	N.D	N.D	<1	3.9	N.D	<0.02	0.08	0.3
108.10.1	8.2	28.8	<5	0.30	0.09	<0.01	3.5	2	3.7	0.003	<0.02	0.09	0.3

文山(洗車班辦公室)

項目	pH	水溫	色度	濁度	硝酸鹽氮	亞硝酸鹽氮	總硬度	大腸桿菌群	溶氧	鉛	自由有效餘氯	氨氮	總有機碳
單位	-	°C	mg/L	NTU	mg/L	mg/L	mg CaCO <sub>3</sub> /L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
標準值	6-8.5	-	5	2	10	0.1	300	6	-	0.01	0.2-1.0	0.1	-
106.5.3	9	25.7	<3	N.D	0.16	N.D	3	<1	-	-	-	-	-
106.7.6	8.8	18.9	<3	N.D	0.27	N.D	4.2	<1	-	-	-	-	-
106.9.5	7.2	30.1	<3	N.D	0.19	N.D	5.2	<1	-	-	-	-	-
106.11.9	7.3	28.8	<3	0.1	N.D	N.D	N.D	<1	-	-	-	-	-
107.1.22	8.1	24.4	<5	0.10	0.23	<0.01	4.0	<1	-	-	-	-	-
107.4.10	8.6	26.4	<5	0.10	0.20	N.D	4.0	<1	-	-	-	-	-
107.7.5	8.4	32.9	<5	0.45	0.26	N.D	8.0	<1	-	-	-	-	-
107.10.11	8.2	28.1	<5	0.10	0.03	N.D	5.0	<1	-	-	-	-	-
108.2.14	7.7	27.3	<5	0.10	0.02	N.D	6.0	<1	4.7	N.D	<0.02	0.05	0.4
108.4.9	8.3	27.2	<5	0.15	0.27	N.D	6.0	<1	2.9	0.003	<0.02	N.D	0.3
108.7.4	8.2	29.1	<5	0.10	0.25	<0.01	N.D	<1	3.9	N.D	<0.02	0.08	0.5
108.10.1	8.2	27.8	<5	0.25	0.20	N.D	4.0	<1	3.3	0.005	<0.02	0.06	0.3

文山(辦公大樓3樓茶水間)

項目	pH	水溫	色度	濁度	硝酸鹽氮	亞硝酸鹽氮	總硬度	大腸桿菌群	溶氧	鉛	自由有效餘氯	氨氮	總有機碳
單位	-	°C	mg/L	NTU	mg/L	mg/L	mg CaCO <sub>3</sub> /L	CFU/100mL	mg/L	mg/L	mg/L	mg/L	mg/L
標準值	6-8.5	-	5	2	10	0.1	300	6	-	0.01	0.2-1.0	0.1	-
106.5.3	8.2	26.2	<3	N.D	0.18	N.D	8.9	<1	-	-	-	-	-
106.7.6	7.5	28.1	<3	N.D	0.28	N.D	5.8	<1	-	-	-	-	-
106.9.5	8.3	29.6	<3	N.D	0.14	N.D	12.2	<1	-	-	-	-	-
106.11.09	8.3	29.0	<3	0.15	N.D	N.D	N.D	<1	-	-	-	-	-
107.1.22	8.1	24.6	<5	<0.10	0.19	<0.01	5.1	<1	-	-	-	-	-
107.4.10	8.4	27.1	<5	<0.10	0.33	N.D	7.1	<1	-	-	-	-	-
107.7.5	8.7	29.8	<5	0.20	0.20	N.D	12.1	<1	-	-	-	-	-
107.10.11	8.9	29.4	<5	0.30	0.23	N.D	12.0	<1	-	-	-	-	-
108.2.14	8.1	28.2	<5	0.40	0.04	<0.01	6.0	<1	4.4	N.D	<0.02	0.05	3.3
108.4.9	8.2	28.4	<5	0.65	0.21	N.D	8.0	<1	2.0	N.D	<0.02	N.D	0.1
108.7.4	8.3	29.5	<5	0.95	0.08	<0.01	N.D	<1	3.8	N.D	<0.02	0.08	1.1
108.10.1	8.4	30.4	<5	0.25	0.19	N.D	6.9	<1	2.1	0.004	<0.02	0.06	0.2